

CERTIFICATE OF COMPLIANCE

Certificate Number E365291
Report Reference E365291-20140226
Issue Date 2020-FEBRUARY-17

Issued to: ROCHESTER GAUGES LLC
11616 HARRY HINES BLVD
DALLAS, TX 75229 USA

**This is to certify that
representative samples of**

TANK-MONITORING EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS

Intrinsically Safe Apparatus for use in Class I, Division 1,
Groups C and D Hazardous Locations.
Liquid Level Probe, Model CLIS Intrinsically Safe for use in
Class I, Groups C and D Hazardous Locations when
installed in accordance with manufacturer's control drawing
no. CLIS-1.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 913, Intrinsically Safe Apparatus and Associated
Apparatus for Use in Class I, II, and III, Division 1,
Hazardous (Classified) Locations
CAN/CSA C22.2 No. 157-92, Intrinsically Safe and Non-
incendive Equipment for Use in Hazardous Locations

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

