

CERTIFICATE OF COMPLIANCE

Certificate Number 20140226-E365291
Report Reference E365291-20140226
Issue Date 2014-FEBRUARY-26

Issued to: FPI SENSORS L L C
SUITE 140, 1301 CORP CTR DR
EAGAN MN 55121

This is to certify that
representative samples of

TANK-MONITORING EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS

Intrinsically Safe Apparatus for use in Class I, Division 1,
Groups C and D Hazardous Locations.
Liquid Level Probe, Model CLIS Intrinsically Safe for use in
Class I, Groups C and D Hazardous Locations when
installed in accordance with manufacturer's control drawing
no. CLIS-1.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


UL 913, Intrinsically Safe Apparatus and Associated
Apparatus for Use in Class I, II, and III, Division 1,
Hazardous (Classified) Locations
CAN/CSA C22.2 No. 157-92, Intrinsically Safe and Non-
incendive Equipment for Use in Hazardous Locations

Additional Information:


See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

